



Umweltschrank mit integrierter Sicherheitsbox

Umweltschrank für die sichere und ordnungsgemäße Lagerung von wassergefährdender Flüssigkeiten mit Sicherheitsbox nach EN 14470-1 (Typ 30) und TRbF 20 (Anhang L) für die ordnungsgemäße Lagerung von feuergefährlichen Stoffen in Arbeitsräumen

MODELL UF.195.95 2-türig

Abmessungen

Außen: ca. 950 x 500 x 1950 (B x T x H) mm

Abmessungen Sicherheitsbox

Innen: ca. 805 x 405 x 405 (B x T x H) mm

Aufbau Schrank

- Außenkorpus aus pulverbeschichtetem Feinstahlblech, Korpus in RAL 5010 (blau), Türen in RAL 7035 (lichtgrau)

Aufbau Sicherheitsbox

- Außenkorpus aus Stahlblech mit Kunststoffbeschichtung in RAL 7035 (lichtgrau)
- Brandschutzisolierung mit aufschäumenden Fugendichtungen

Bedienung/Schließung/Verriegelung

- Umweltschrank mit 2 Flügeltüren und integrierter Verriegelung
- Türen mit einem Sicherheitsschloss abschließbar
- Sicherheitsbox mit 2 selbstschließenden Flügeltüren

Ausstattung

- Umweltschrank mit 3 höhenverstellbaren Auffangwannen (Rastermaße 25 mm) kipp- und auszugssicher, verzinkte Auffangwanne gemäß StawaR (20Liter Auffangvolumen je Wanne)
- Sicherheitsbox mit integrierter Auffangwanne aus Stahlblech

Zubehör

- Zusätzliche Auffangwanne, verzinkt
- Lochblecheinsatz für Auffangwannen, Edelstahl
- PE Auffangwanne für die Feuerverzinken Auffangwannen
- Zusätzliche Fachböden, aus Stahlblech pulverbeschichtet in der Sicherheitsbox.
- Chemikalien Box aus PPS, Flüssigkeitsundurchlässig mit Griffen und Deckel

Lüftung

- Abluftanschluss (NW 75) für die Sicherheitsbox auf der Schrankaußenseite

Kennzeichnung

- Umweltschrank Kennzeichnung gemäß der Gefahrstoffverordnung
- Sicherheitsbox gemäß EN 14470-1

Dokumente zur Vorlage (Sicherheitsbox)

- Prüfungsbericht der typenbezogenen Brandprüfung nach DIN EN 14470-1
- Prüfbescheinigung nach dem Gerätesicherheitsgesetz
- CE-Konformitätsbescheinigung (auch Richtlinie 94/9/EG (ATEX), Kennzeichnung CE II 2G T6)
- Zertifikat zur Fremdüberwachung durch eine anerkannte Materialprüfanstalt



Environmental cabinet with integrated safety box

Environmental cabinet for the correct storage of water-endangering liquids with safety box after EN 14470-1 (Type 30) and TRbF 20 (appendix L) to the correct storage of combustible liquids in work areas

MODELL UF.195.95 2-doors

Dimension

Exterior: approx. 950 x 500 x 1950 (W x D x H) mm

Safety box dimensions

Interior: ca. 805 x 405 x 405 (W x D x H) mm

Construction of the cabinet

- Cabinet housing is made of powder-coated sheet steel, corpus in RAL 5010 (blue), doors in RAL 7035 (light grey)

Construction of safety box

- Exterior corpus is made of sheet steel with plastic coating in RAL 7035 (light grey)
- Fire protection isolation also intumescent joint sealing

Operating/locking/bolting device

- Environmental cabinet with 2 wing doors and integrated connecting rod bolting device
- Doors with a safety lock lockable
- Safety box with 2 self-closing wing doors

Equipment

- o Environmental cabinet with 3 adjustable (modular dimension 25 mm) tilting and draw-out-secured, galvanized catch pans in accordance with StawaR (catching volume 20 l for each sump)
- Safety box with integrated sump made of sheet steel

Accessories

- Additional catch pans, galvanized
- Perforated metal plate insert for catch pans, stainless steel
- PE sump for inserting into the galvanized sump
- Additional shelves, sheet steel powder coated, inside the cabinet safety box
- Chemical box made of PPS, impervious to liquids with handles and covers
- Storing box made of sheet steel, separately lockable

Exhaust

- Exhaust connection (NW 75) for the safety box on the cabinet cover

Labelling

- Environmental cabinet in accordance with dangerous material regulation
- Safety box according with EN 14470-1

Documentation to the collecting main (safety box)

- Examination report of the type-referred fire examination after EN 14470-1
- Inspection certificate according with the equipment safety law
- CE conformance certificate (including guideline 94/9/EC (ATEX), marking CE II 2G T6)
- Certificate for external supervision by a recognized material test institute